

भारत सरकार
श्रम एवं रोजगार मंत्रालय
खान सुरक्षा महानिदेशालय
विद्युत मुख्यालय : धनबाद

संख्या 1080

/वि० मु०, धनबाद, दिनांक 31-05 : 2013

प्रेषक :

खान सुरक्षा महानिदेशक
खान सुरक्षा महानिदेशालय
धनबाद-826 016.

सेवा में

स्पीड पोस्ट

मेसर्स सुधीर स्वीचगीयर्स प्रा० लि०
305/6, अपीजे हाउस
130, मुम्बई समाचार मार्ग
फोर्ट, मुम्बई-400 023.

विषय : ज्वालारोधी व मौशमरोधी मशीन (अनुलग्न-ए में वर्णित) का तेल खान में प्रयोग हेतु डी०जी०एम०एस० क्षेत्रीय परीक्षण अनुमति पत्र - निर्माता मेसर्स सुधीर स्वीचगीयर्स प्रा० लि०, मुम्बई-400 023.

महोदय,

उपरोक्त विषय से संबंधित क्षेत्रीय परीक्षण अनुमति पत्र अग्रेषित किया जाता है ।

भवदीय,

११३६
२९.०५.१३

(राहुल गुहा)
खान सुरक्षा महानिदेशक

S-29020/208/75(2)/FTP/2009/EHQ

भारत सरकार Govt. of India

श्रम एवं रोजगार मंत्रालय Ministry of Labour & Employment

खान सुरक्षा महानिदेशालय Directorate General of Mines Safety

विद्युत मुख्यालय: धनबाद Electrical Head Quarter: Dhanbad

No. 1080 /EHQ, Dhanbad, dated the 31-05 : 2013

From: The Director General of Mines Safety
DGMS : Dhanbad-826 016.

To Speed Post

M/S Sudhir Switchgears Pvt. Ltd.
305/6, Apeejay House
130, Mumbai Samachar Marg
Fort, Mumbai-400 023.

Sub:- Permission for field trial of flameproof/weatherproof electrical equipment as mentioned in Annexure-A conforming to IS/IEC 60079-1:2007, IS/IEC 60529 : 2001 and IS/IEC 60079-0:2004 manufactured by M/S Sudhir Switchgears Pvt. Ltd., Mumbai for use in Zone-1 and Zone-2 hazardous areas of Oil Mines under Regulation 75(2) of the Oil Mines Regulations, 1984.

Dear Sir,

With reference to your application Nos. SSPL/THN/DGMS/2011/04 dated 27.12.2011 and SSPL/DGMS/13-14/01 dated 27.04.2013 on the above mentioned subject.

Based on CIMFR test certificates, the flameproof/weatherproof electrical equipment (as mentioned in Annexure-A) may be put on field trial in any oil mine of M/S ONGC Ltd., Ankaleshwar Asset, Ankaleshwar (Gujarat) subject to the following conditions:-

1. The installation, operation and maintenance of the above equipment shall be carried out under the direct supervision of the manufacturer and in accordance with the relevant provisions of the Central Electricity Authority (Measures relating to Safety and Electric Supply) Regulations, 2010.
2. The duration of the field trial shall not be less than **three (03) months**. During this period, manufacturer shall maintain close rapport with the user so as to facilitate satisfactory field trial of the equipment.
3. A copy of the instruction manual, if any, on installation, maintenance and operation of the equipment shall be handed over to the user.
4. The name of the mine, where the equipment are installed shall be intimated to the Director of Mines Safety (Elect.), North-Western Zone, Udaipur through Dy. Director General of Mines Safety, North-Western Zone, Udaipur and to this Directorate immediately thereafter.

Contd...P-2

[Handwritten Signature]
21/05/13
क. न. पं. डे. न.

7

: 2 :

5. Final approval of the equipment shall be considered only on receipt of satisfactory performance report thereof from the user as well from the field officer of this Directorate.
6. The rating of the equipment in the final approval will be based on the rating at which the equipment was field tried.
7. The equipment shall be efficiently protected against any mechanical injury by adopting proper means of laying and maintenance of the same.

This permission is issued exclusively for the purpose of field trial, which is liable to be withdrawn / modified, if considered so necessary and revoked, in case of any of the conditions subject to which this permission is issued, being violated or not complied with. This field trial permission is valid for one year from the date of issue of this letter. If the formalities for issue of final approval are not completed during this period, this field trial permission would stand withdrawn.

Please communicate the compliance of the above conditions.

Yours faithfully,



29.5.13
(Rahul Guha)

Director General of Mines Safety

Annexure-A

List of flameproof/weatherproof electrical equipments manufactured by M/S Sudhir Switchgears Pvt. Ltd., Mumbai conforming to IS/IEC 60079-1:2007, IS/IEC 60529 : 2001 and IS/IEC 60079-0:2004 for field trial to be used in Zone-1 and Zone-2 hazardous areas of Oil Mines of M/S ONGC Ltd., Ankleshwar Asset, Ankleshwar issued vide Directorate's letter No...1080...../EHQ dated.....31-05-2013..

Sl. No.	Name of the electrical equipments	CIMFR test report Nos.
1.	Flameproof/weatherproof enclosure for Control Panel, in cast aluminium alloy LM-6 construction designated by Cat. No. RCP/215	CIMFR/TC/SR/638 dated 30.08.2012
2.	Flameproof/weatherproof (IP-65) Panel Board, in cast aluminium alloy LM-6 construction, designated by Cat. No. RCP/221	CIMFR/TC/SR/141 dated 03.05.2012
3.	Flameproof/weatherproof (IP-66) Hand Lamp Fitting, in cast aluminium alloy LM-6 construction, designated by Cat. No. HL/2C/126	CIMFR/TC/SR/1504 dated 16.02.2012


(Rahul Guha)

Director General of Mines Safety

O/C Office
27/05/13

3-11-113
27/5/2013

भारत सरकार
श्रम एवं रोजगार मंत्रालय
खान सुरक्षा महानिदेशालय
विद्युत मुख्यालय : धनबाद

संख्या 1084

/वि० मु०, धनबाद, दिनांक 31-05 : 2013

प्रेषक :

खान सुरक्षा महानिदेशक
खान सुरक्षा महानिदेशालय
धनबाद-826 016.



सेवा में

स्पीड पोस्ट

मेसर्स सुधीर स्वीचगीयर्स प्रा० लि०
305/6, अपीजे हाउस
130, मुम्बई समाचार मार्ग
फोर्ट, मुम्बई-400 023.

विषय : ज्वालारोधी व मौशमरोधी मशीन (अनुलग्न-ए में वर्णित) का तेल खान में प्रयोग हेतु डी०जी०एम०एस० क्षेत्रीय परीक्षण अनुमति पत्र - निर्माता मेसर्स सुधीर स्वीचगीयर्स प्रा० लि०, मुम्बई-400 023.

महोदय,

उपरोक्त विषय से संबंधित क्षेत्रीय परीक्षण अनुमति पत्र अग्रेषित किया जाता है ।

भवदीय,

१.३६
२९.५.१३

(राहुल गुहा)

खान सुरक्षा महानिदेशक

S-29020/207/75(2)/FTP/2009/EHQ

भारत सरकार Govt. of India

श्रम एवं रोजगार मंत्रालय Ministry of Labour & Employment

खान सुरक्षा महानिदेशालय Directorate General of Mines Safety

विद्युत मुख्यालय: धनबाद Electrical Head Quarter: Dhanbad

No. 1084 /EHQ, Dhanbad, dated the 31-05 : 2013

From:

The Director General of Mines Safety
DGMS : Dhanbad-826 016.

To

Speed Post

M/S Sudhir Switchgears Pvt. Ltd.
305/6, Apeejay House
130, Mumbai Samachar Marg
Fort, Mumbai-400 023.

Sub:- Permission for field trial of flameproof/weatherproof electrical equipment as mentioned in Annexure-A conforming to IS/IEC 60079-1:2007, IS/IEC 60529 : 2001 and IS/IEC 60079-0:2004 manufactured by M/S Sudhir Switchgears Pvt. Ltd., Mumbai for use in Zone-1 and Zone-2 hazardous areas of Oil Mines under Regulation 75(2) of the Oil Mines Regulations, 1984.

Dear Sir,

With reference to your application Nos. SSPL/THN/DGMS/2012/COR-2 dated 21.03.2013 and SSPL/DGMS/13-14/01 dated 27.04.2013 on the above mentioned subject.

Based on CIMFR test certificates, the flameproof/weatherproof electrical equipment (as mentioned in Annexure-A) may be put on field trial in any oil mine of M/S ONGC Ltd., Ankaleshwar Asset, Ankaleshwar (Gujarat) subject to the following conditions:-

1. The installation, operation and maintenance of the above equipment shall be carried out under the direct supervision of the manufacturer and in accordance with the relevant provisions of the Central Electricity Authority (Measures relating to Safety and Electric Supply) Regulations, 2010.
2. The duration of the field trial shall not be less than **three (03) months**. During this period, manufacturer shall maintain close rapport with the user so as to facilitate satisfactory field trial of the equipment.
3. A copy of the instruction manual, if any, on installation, maintenance and operation of the equipment shall be handed over to the user.
4. The name of the mine, where the equipment are installed shall be intimated to the Director of Mines Safety (Elect.), North-Western Zone, Udaipur through Dy. Director General of Mines Safety, North-Western Zone, Udaipur and to this Directorate immediately thereafter.

Contd...P-2

[Handwritten Signature]
27/05/13
[Handwritten Initials]

: 2 :

5. Final approval of the equipment shall be considered only on receipt of satisfactory performance report thereof from the user as well from the field officer of this Directorate.
6. The rating of the equipment in the final approval will be based on the rating at which the equipment was field tried.
7. The equipment shall be efficiently protected against any mechanical injury by adopting proper means of laying and maintenance of the same.

This permission is issued exclusively for the purpose of field trial, which is liable to be withdrawn / modified, if considered so necessary and revoked, in case of any of the conditions subject to which this permission is issued, being violated or not complied with. This field trial permission is valid for one year from the date of issue of this letter. If the formalities for issue of final approval are not completed during this period, this field trial permission would stand withdrawn.

Please communicate the compliance of the above conditions.

Yours faithfully,



(Rahul Guha)

Director General of Mines Safety

Annexure-A

List of flameproof/weatherproof electrical equipments manufactured by M/S Sudhir Switchgears Pvt. Ltd., Mumbai conforming to IS/IEC 60079-1:2007, IS/IEC 60529 : 2001 and IS/IEC 60079-0:2004 for field trial to be used in Zone-1 and Zone-2 hazardous areas of Oil Mines of M/S ONGC Ltd., Ankleshwar Asset, Ankleshwar issued vide Directorate's letter No. 1. 0. 8. 4 /EHQ dated... 31. 0. 5. 2013...

Sl. No.	Name of the electrical equipments	CIMFR test report Nos.
1.	Flameproof/weatherproof enclosure for well glass lighting fitting with built in control gear box, in cast aluminium alloy LM-6 construction designated by Cat. No. WG/1235 rated 250 W HPMV/150 W metal halide lamp at 250 V AC / DC max.	CIMFR/TC/SR/H834 dated 22.03.2013
2.	Flameproof/weatherproof (IP-66) well glass fitting, in cast aluminium alloy LM-6 construction, designated by Cat. No. WG/2C/1236 rated 400 W HPMV/500 W GLS/250 W metal halide lamp/3X36 W CFL at 250 V AC/DC max., 50 Hz	CIMFR/TC/SR/H139 dated 25.05.2012
3.	Flameproof/weatherproof (IP-66) Flood Light Fitting, in cast aluminium alloy LM-6 construction, designated by Cat. No. FL/2C/151 rated upto 250 W HPMV/300 W GLS/150 W metal halide lamp rated for upto 415 V AC/DC(max.)	CMRI/TC/P/H63 dated 24.04.2006


29.5.13
(Rahul Guha)

Director General of Mines Safety